



<b>HFE ITEMS IN ELECTRICAL SAFETY CHECKLIST</b>	
<b>CRITERIA</b>	<b>DESCRIBE REPOSE</b>
1. Lock-out/tag-out devices?	
2. Disconnecting means for motors and appliances been legibly marked or identified	
3. Adequate space around the equipment for safe operation, access, egress, and maintenance	
4. Adequate illumination and identification of Safety Showers - Eyewash Stations	
5. Disconnecting means provided for stationary battery banks	
6. Power supplies for essential services	
7. Emergency lighting fixtures	
8. "Exit lights" in all buildings normally occupied by personnel	
9. Operating handles for switches, circuit breakers, etc., designed to be no more than 6 feet 6 inches above the floor	