



<b>HFE ITEMS IN FIRE PROTECTION SAFETY CHECKLIST</b>	
<b>CRITERIA</b>	<b>DESCRIBE REPOSE</b>
1. Have the requirements for fire detection and alarm systems been provided for buildings?	
2. Have the requirements for fire detection and alarm systems been provided for outside process areas?	
3. Are fire detection and alarm systems designed in accordance with NFPA 72? If not, what applicable industry code or standard?	
4. Is adequate access provided for escape routes, etc?	
5. Have an adequate number of Life Vest been provided?	
6. Have an adequate number of Life Ring Buoys and Life Boats been provided?	
7. Are hand and portable extinguishers furnished in accordance with NFPA 10, "Standard for Portable Fire Extinguishers?"	
8. What type of actuation has been provided (manual, automatic, or both)? Be aware that manually operated systems may be justified when accidental system discharge would result in extensive damage to contents and equipment?	
9. Are Escape Craft required and provided for maximum expected occupancy?	