



HFE ITEMS IN SYSTEMS SAFETY CHECKLIST	
CRITERIA	DESCRIBE REPOSE
1. If any plant interlock must be bypassed for startup or shutdown, has the impact of this been addressed?	
2. Have the locations of critical valves and/or controls been identified? (e.g., valves on piping delivering snuffing steam to furnaces, valves which isolate specific equipment, etc.)	
3. Have changes which occurred after the DHR been documented and approved and their impact on safety and health of plant operators (been) addressed?	
4. Is personnel protection for hot/cold services shown where required?	